


# Potential Ventilation System Modifications CoA B5 Report



## NorthConnex Project

## Lendlease Bouygues Joint Venture

		Position	Signed / Authorised Date
--	--	----------	-----------------------------

Document Number:  
NCX-LLB-01-0100-RG-RP-0002

Revision: 04



## Document Control

Title:	Plan Title	Document No/Ref: ALL-LLB-01-0100--RP- 0002
General Description:	Potential Ventilation System Modifications - CoA B5 Report	
Document Path:	S:\400B Engineering\470B Data All\05_Reports\04_Design Reports\A20_CoA B5 additional tunnel ventilation\2017 revision\FINAL_aug 17 \NCX-LLB-01-0100-RG-RP-0002 Potential Ventilation System Modifications CoA B5 Report	
Document Template:	Plan_Procedure: Version 12 June, 2015	

## Revision

Revision	Date	Description	Section/Page No.	Approved
Revision 01	19/02/2016	CoA B5 Report	Entire Document	
Revision 02	04/03/2016	CoA B5 Report	Entire Document	
Revision 03	July 2017	CoA B5 Report	Entire Document	
Revision 04	Feb 2018	CoA B5 Report	Entire Document	

# Contents

Terms and Definitions .....	5
Executive Summary .....	6
1. Introduction .....	7
1.1. Background .....	7
1.2. Purpose of this Report .....	7
2. Systemic Exceedances of Tunnel Ventilation Requirements .....	12
3. Nature of Potential Exceedance Events .....	13
4. Tunnel Ventilation Design Requirements .....	14
4.1. Design Criteria .....	14
4.2. Tunnel Ventilation Concept .....	16
4.3. System Usage – Concept Design .....	17
4.3.1. Jet Fan Usage .....	17
4.3.2. Axial Fan Usage – Intermediate Smoke Extraction Stations .....	18
4.3.3. Axial Fan Usage – North and South Ventilation Stations .....	18
5. Operational Traffic Management and Enforcement Provisions .....	19
6. Modification Concepts .....	20
6.1.1. Considerations for Ventilation Modifications .....	20
6.1.2. Constraints on Potential Modifications .....	20
6.1.3. Potential Future Modifications .....	21
6.1.4. Assessment Methodology of Potential Modifications .....	20
6.1.5. Potential Modification #1 – Additional Jet Fans .....	17
6.1.6. Potential Modification #2 – Additional Capacity of Outlet Axial Fans .....	24
6.1.7. Potential Modification #3 – Conversion of Wilson and / or Trelawney to Ventilation Outlets and Air Intakes .....	25
6.1.8. Potential Modification #4 – Tunnel Air Filtration .....	27
6.1.9. Potential Modification #5 – Tunnel Outlet Filtration .....	29
6.1.10. Prioritising Potential Modifications .....	31
7. Potential Modifications Identified .....	32

# Appendices

Appendix 1: Approved Air Quality Criteria.....	35
Appendix 2: Tunnel Ventilation Design Criteria.....	38
A2 Tunnel Ventilation Design Requirements.....	39
A2.1 Design Criteria.....	39
A2.1.1 Normal Operation Requirements.....	39
A2.1.2 Congested Operation Requirements.....	39
A2.1.3 Emergency Operation Requirements.....	39
A2.1.4 Traffic Density/Fleet Mix.....	39
A2.1.5 In-Tunnel Air Quality Limits.....	39
A2.1.6 Ventilation Outlet Limits.....	39
A2.1.7 Vehicle Emissions.....	40
A2.1.8 Emission Conversion Factors.....	40
A2.1.9 Visibility to Solid Particle Conversion.....	40
A2.1.10 VOC:CO Ratio.....	40

## Terms and Definitions

Term	Definition
BYCA	Bouygues Construction Australia Pty
Client	NorthConnex Project Company and NorthConnex State Works Contractor (together the Project Company Group) under the NorthConnex D&C Deed; The Hills Motorway Limited under the M2 Integration D&C Deed.
D&C	Design and Construction
Deed	As appropriate to the defined scope of the NorthConnex D&C Deed OR the M2 Integration D&C Deed
IC	Independent Certifier – APP Corporation Pty Limited engaged in accordance with either the NCX or M2I Independent Certifier Deeds.
IFC	Issued For Construction
LLBJV	Lend Lease Bouygues Joint Venture (Contractor)
LLEMS	Lend Lease Engineering Management System
M2I	M2 Integration
NCX	NorthConnex
NSW	New South Wales
NWRL	North west Rail Link
PCU	Passenger Car Unit – a standard, consistent basis for accounting for the amount of road space taken up by different size vehicles.
Piston effect	Air flow in a tunnel that is generated by, and in the direction of, moving vehicles.
PMP	Project Management Plan
PMS	Project Management System
Project	NorthConnex and M2 Integration Projects
Project Company	NorthConnex Company Pty Ltd, which acts on behalf of the Client's under both the NCX D&C Deed and the M2I D&C Deed.
Project Company Group	NorthConnex Company Pty Ltd (Project Company) and NorthConnex State Works Contractor Pty Ltd
QP	Quality Plan
Sub IC	Sub Independent Certifier - APP Corporation Pty Limited engaged in accordance with either the NCX OR M2I Sub Deed of Appointment of Independent Certifier.
SWTC	As appropriate to the defined scope of the Scope of Works & Technical Criteria defined as Exhibit A under the individual NorthConnex D&C Deed OR the M2 Integration D&C Deed
















Figure 2-5 Design analysis A (PCU) relative to traffic design capacity

## Report by the Advisory Committee on Tunnel Air Quality, NSW

The Secretary, Department of Planning & Environment requested the Chief Scientist and Engineer (as Chair of the Advisory Committee on Tunnel Air Quality - ACTAQ) for the ACTAQ to provide advice on the appropriateness of the air quality modelling and predicted air quality outcomes contained in the EIS for the NorthConnex Project. The Final Review Report was provided to the Secretary 04 December 2014.

The review was conducted by Dr Ian Longley, National Institute of Water and Atmospheric Research, Auckland,, New Zealand and Professor Peter Sturm, Graz University of Technology, Austria. Dr Longley is an Independent Expert for the ACTAQ. Dr Sturm is a Technical Advisor to the ACTAQ.

The main findings of the review of the EIS and SPIR are as follows:

- i. The description of how in-tunnel air quality is assessed and maintained is now consistent and clear;
- ii. The ventilation design incorporates sufficient spare capacity to provide the operators with sufficient flexibility to meet in-tunnel exposure standards.

## 2. Systemic Exceedances of Tunnel Ventilation Requirements

The tunnel ventilation system has been designed on a set of criteria and standards that provide a robust and integrated systems design. It incorporates a comprehensive integrated method of automatically sensing traffic flows and speed, a number of in-tunnel air monitoring system points, and automatic adjustment of tunnel jet fans to maintain the required air flow to provide the specified in-tunnel air quality.

Maximum vehicle volumes are a 60kmph traffic volume of 4000 PCU / hr / 2-lane tunnel carriageway. As traffic speeds decrease the vehicle volumes per unit of time decrease so that 20kmph traffic volume is 2838 PCU / hr / 2 lane carriageway,

As demonstration of system compliance with the stipulated air quality goals, the tunnel ventilation system air quality is required to be monitored, and any exceedances of the air quality criteria are to be notified within 24 hours. The requirements on Notification and Reporting of In-Tunnel Air Quality are detailed in Condition E5 and E6.

Similar monitoring, notification and reporting are required for the ventilation outlets as detailed in Condition E10 and E13. Note, Condition E12 requires that the ventilation outlet limits be reviewed every 5 years, and the current approved limits lowered (made more stringent) if there are improvements in vehicle fleet emissions.

Ambient air quality goals are detailed in Condition E8, with notification and reporting requirements detailed in Condition E9.

When notified of exceedances the Secretary, DoPE, shall consider the circumstances of the event, including:

- i. The nature of the event, including details relating to the cause
- ii. The duration of the event;
- iii. The extent and severity of the event
- iv. The frequency of the event, including whether an event with the same or similar circumstances has occurred previously.
- v. The measures employed to minimise the concentration levels or to improve the visibility levels.

Based on an assessment of the circumstances, the Secretary, DoPE, may request a Tunnel Air Quality Management Systems Effectiveness Report. This 'Systems Effectiveness' Report is to detail:

- Overall performance and concentration levels in the tunnel or outlets over the preceding 6 months, providing average and maximum levels and the respective time periods
- Details where pollutant levels during operations have exceeded the specified limits
- Consideration of how the tunnel air quality management can be improved including installation of additional ventilation management facilities outlined in this 'Potential Modifications' Report.

### 3. Nature of Potential Exceedance Events

Exceedances of air quality limits could occur from a number of likely events, some of which have a level of predictability as to when they would occur, or others that are likely to occur but the actual occurrence cannot be predicted. These events have been classed as:

- External Events; and
- Internal Events

Therefore the potential events have been categorised as follows:

- External Predictable Events: Traffic congestion on downstream Motorways in holiday or other periods. There is extensive information available on the characteristics of peak traffic periods to assist the traffic management systems coordinated with the management of tunnel ventilation .
- Internal Predictable Events: Consequent to the above predictable event there is a potential consequent slow moving traffic within the tunnel in holiday or other periods. Again, there is extensive information available on the characteristics of peak traffic periods to assist. the traffic management systems coordinated with the management of tunnel ventilation
- External Un-Predictable Events: These could arise from:
  - Bushfires, or dust events,
  - adverse weather patterns (thermal inversions that may affect air dispersion),
  - unpredicted loss of power to a wide area (both supplies); and
  - major downstream traffic accidents, either within the tunnel or external to the tunnel, blocking lanes and causing prolonged congestion.

These un-predicted events will require different responses that actively manage the tunnel traffic (such as, diverting traffic to recognised detour routes), increase in tunnel ventilation to ensure that air quality limits are maintained, or are restored as quickly as possible.

- Internal Irregularities and Abnormalities in Measurements: There are 'potential exceedances' that may arise from a number of factors such as:
  - Measurement of small concentrations in a large dynamic airstream that will contain vortices and eddies, and thus is not evenly mixed, caused by vehicles moving faster through the airstream;
  - Order of accuracy of the measurement method and equipment.

There is another potential category, 'Un-anticipated Errors in Design Information". This is highly unlikely but could arise from errors from:

- Tunnel traffic volumes higher than the ventilation design assumptions;
- Vehicle emissions being substantially different from the design assumptions, either from changes in fleet mix, changes in assumed heavy vehicle volumes, or fuel types;
- Conversion ratios adopted for NO<sub>x</sub> and NO<sub>2</sub>, visibility to solid particles, and the VOC to CO ratio.

## 4. Tunnel Ventilation Design Requirements and Concept Design

### 4.1. Design Criteria

The tunnel M&E Systems are designed to meet a two lane configuration based on defined criteria of a maximum traffic volume and speed, and defined emissions data. A summary of the design criteria for the Tunnel Ventilation System is included in Appendix 2 of this report.

#### Passenger Car Unit

A key determinant is the theoretical maximum capacity of a traffic lane, and by extension, the theoretical maximum capacity of the mainline tunnel. International standards for traffic capacity are based on a 'passenger car unit'.

As outlined in the EIS and concisely explained in Section 2.5.1 of the SPIR (page 58), " *Passenger car units* is a standard, consistent basis for measuring the 'space' taken up by different size vehicles. For example:

- A standard passenger vehicle is one passenger car unit.
- An articulated truck is 2.9 passenger car units.
- A truck and dog is two passenger car units.

*This relationship between the theoretical motorway lane 'throughput capacity' and average traffic speed is illustrated in Figure 2-1. The figure shows that:*

- *A maximum motorway lane capacity of 2,000 passenger car units per lane per hour is achievable at an average traffic speed of 60km/h. This means that 2,000 passenger car units could pass a fixed monitoring point on a motorway lane every hour if traffic is travelling at 60km/h.*
- *At an average traffic speed of 80km/h, a greater stopping distance is required between vehicles. Because of this, only 1740 passenger car units would pass the same fixed point on a motorway lane per hour.*
- *At an average speed of 40km/h, a shorter stopping distance is required between vehicles, but the vehicles are moving more slowly. Because of this, only 1849 passenger car units would pass the same fixed point on a motorway lane per hour. For 20km/h, this figure would drop further to only 1419 passenger car units per hour."*

NorthConnex mainline tunnels are two lanes, therefore the theoretical capacity of the mainline tunnel is doubled to 4,000 passenger car units per hour at 60km/h.




Figure 2-1 Relationship between motorway lane capacity and average traffic speed

## Tunnel Alignment Design


A tunnel vertical alignment is a contributor to vehicle emissions. The physical alignment of the NorthConnex tunnel has been designed to minimise, as far as is reasonably practicable, the effects of gradient on the vehicle emissions.

The tunnel connects the Hills M2 Motorway near the junction of Pennant Hills Rd to the M1 Pacific Motorway between the North Shore Rail overbridge and Edgeworth David Rd overbridge. The tunnel provides free flow mainline to mainline connections to both Motorways. There are on-ramps and off-ramps connecting to Pennant Hills Road at both the north and south ends of the tunnel.

The vertical alignment of the tunnel is dictated by two principle constraints:

- Topographical level difference between the Hills M2 northbound connection to the M1 Motorway northbound connection of approximately 50m, and
- Placing the tunnels below the NWRL tunnels to optimise the vertical gradient. There is a resulting vertical climb of approximately 91m over about 7.5km in the northbound tunnel. The resulting northbound gradient is approximately 1 percent, with a short length of 4 percent to exit the tunnel to the M1 Motorway.

The effect of the tunnel gradient on the vehicle emissions such that the northbound mainline tunnel requires more jet fans than are required in the southbound mainline tunnel. That is predominantly uphill northbound versus predominantly downhill southbound.



## 2.2 Northbound Mainline Tunnel – Diagrammatic Alignment

Key determinants of the ventilation system design are:

1. The number of vehicles and the sensitivity of the predicted numbers
2. The fleet mix, particularly the fuel type and the proportion of Heavy Goods Vehicles (HGV)
3. Air quality in the tunnel, and in the outlets prior to dispersion
4. The ambient air quality outside the tunnels. First as the source of ‘fresh air’, and second as the environment for dispersion of the tunnel air from the outlets.

The sensitivity of the base data is potentially affected by significant changes in the total number of vehicles, and then the proportion of Heavy Goods Vehicles to the remaining vehicles. The tunnel ventilation design adopts the PIARC recommendation of a maximum theoretical throughput 4000 PCU /hr at 60 km/h for each carriageway northbound and southbound.


## 4.2. Tunnel Ventilation Concept

The tunnel ventilation concept at the highest level is essentially two basic components. They are a longitudinal ventilation system of the tunnel carriageway, with extraction to an outlet at the end. The tunnel ventilation system is made up of a number of components that are automatically controlled to meet the normal and emergency ventilation requirements of the system. These components include:

- Jet Fans (installed within the tunnel for longitudinal airflow control);
- Axial Fans (installed within the ventilation station for extraction or supply of air);
- Attenuators (installed within the ventilation station to limit the transmission of noise);
- Dampers (installed to control the flow path of air); and
- Sensors (installed to provide feedback to the control system).


The systems control incorporates a manual override to enable operator intervention and direct control.

The mainline entry, on-ramp entry tunnel, intermediate emergency extraction or air supply points, off ramp exit tunnel, and mainline exit tunnel divides the carriageway ventilation into eight sections.






## 4.1 - Northbound Tunnel Sections



## 4.2 - Southbound Tunnel Sections

The concept entails that ambient air is drawn in at the portals and is moved by a combination of piston effect from vehicles and air movement by entraining air through action of the jet fans. Air is moved in the direction of the traffic flow, except for the exit ramps where air is drawn down the ramp to the mainline tunnel.

Air quality is automatically measured at a number of set points along the tunnel to provide direct real time air quality data to the Control System.



## 4.3 Diagram – Submissions and Preferred Infrastructure Report

### 4.3. System Usage – Concept Design

#### 4.3.1. Jet Fan Usage

Jet fans are automatically controlled to achieve the set points programmed into the tunnel ventilation control system (part of the tunnel control system). If a change in airflow set points is required, this can be achieved by updating the values programmed into the tunnel ventilation control system, subject to the capacity of the existing system.

The capacity of the jet fan system is being designed based on the PIARC maximum traffic throughput of 2000 pcu/hr/lane at 60km/h which the speed is providing the maximum throughput of vehicles per hour. That is, each tunnel mainline carriageway is designed for 4000 PCU / hr.

Based on the traffic mix specified (cars and heavy goods vehicles), this equates to approximately 3200 vehicles per hour per 2-lane tunnel. Note: EIS and SPIR predicted traffic volumes at 2029 are significantly less than this, in the order of 50%.

On these predicted traffic volumes, under free flowing conditions the number of jet fans required in the northbound tunnel is approximately 15 out of the 72 jet fans installed (approximately 20% of the installed capacity), with the southbound tunnel using a similar percentage of the installed jet fan capacity under the corresponding scenario.

### 4.3.2. Axial Fan Usage – Intermediate Smoke Extraction Stations

Each of the Smoke Extraction ventilation stations at Wilson Road and Trelawney Street used for extraction of smoke or other pollutants in an emergency have four (4) axial fans designed in a three duty plus one standby configuration. In an emergency, extraction rates will be controlled to maintain tenable conditions within the Incident Tunnel.

The EIS and SPIR identified that during congested conditions, fresh air would be supplied at these locations to the tunnels, but no extraction of contaminated air. This would be achieved by running the extract fans in reverse, which is supply air to the tunnel, instead of exhausting smoke. The amount of air that can be provided at these points, without extracting air, is limited to approximately  $200\text{m}^3/\text{sec}$  into each tunnel.

### 4.3.3. Axial Fan Usage – North and South Ventilation Stations

Each of the main portal ventilation stations used for extraction of vitiated air from the tunnel are installed with five (5) off axial fans designed in a four duty plus one standby configuration to provide a total nominal 800 m<sup>3</sup>/s flow rate at the Northern Ventilation Facility and a 800 m<sup>3</sup>/s flow rate at the Southern Ventilation Facility. For energy consumption reasons however, the system will operate all five (5) fans at a reduced speed to provide the duty airflow. It should be noted that the HV cabling in the tunnels will be sized for a maximum electrical demand of 25MVA whereas the current estimate of the required duty is 22MVA.

If an increased flow rate is required from the existing fans, this may be possible by operating the five (5) off fans at an increased speed. The extra amount that could be obtained is not expected to be significant, and in any case can only be confirmed subject to final fan selections.

A consequence of operating all five (5) off axial fans at higher speeds includes potential impacts to ambient noise levels. It may be possible to mitigate the impact of the additional noise through installation of additional noise attenuation into the existing ventilation facilities.

Similar to the jet fan usage described above, the installed capacity of the axial fan system is based on the PIARC maximum traffic throughput rather than the predicted traffic levels for the tunnel. In this case the defining scenario for the axial fan system is the PIARC maximum traffic throughput of approximately 1740 pcu/hr/lane at 80km/h or approximately 1400 vehicles per hour per lane based on the traffic mix. Given the predicted traffic numbers are significantly below this nominated throughput, the axial fan capacity required in the northbound tunnel is approximately 560 m<sup>3</sup>/s compared to the 800 m<sup>3</sup>/s of the installed capacity provided at the Northern Ventilation Facility. This equates to approximately 70% of the installed capacity.

## 5. Operational Traffic Management and Vehicle Enforcement Provisions

There are a number of measures that assist in maintaining air quality within the tunnel that are not part of the ventilation system. These are:

- Smokey Vehicle Enforcement – being provided as part of the NorthConnex Project within both mainline tunnels;
- Traffic management devices such as ramp metering of the on-ramps, lane closure medians external to the tunnel to limit the amount of traffic entering the tunnel in the case of heavy congestion and slow traffic

## 6. Modification Concepts

### 6.1.1. Considerations for Ventilation Modifications

Notwithstanding the robust design of the ventilation system (as outlined in the SPIR Section 7.1.1.3, it is designed for approximately double the 2019 predicted traffic volumes), the intent of Condition B5 is to consider what modifications or additional improvements are capable of being provided so that the air quality limits are able to be maintained, if there are repeated exceedances of air quality limits.

These modifications to the overall tunnel ventilation design have potential effects on a number of other tunnel systems, and potentially impacts to the tunnel civil design if additional space is required. The ventilation system, power distribution system and control system are intimately linked, so changes made to the ventilation system will have an impact on these other systems. For example, an increase in the number of jet fans within the tunnel increases the overall power demand, and potentially an increase in the size of the power reticulation system.

### 6.1.2. Constraints on Potential Modifications

The constraints associated with the civil and associated services design also need to be considered. Several of these are either infeasible or unreasonable to alter. Examples of this include

- The cross sectional area of the tunnel **mainline carriageways and tunnel ramps**;
- **The cross sectional area of the ventilation outlets**
- **The cross sectional area of the ventilation inlets, both the entry portals and the intermediate facilities at Wilson Road and Trelawney Street.**
- **Potential constraints on the spatial enlargement for additional equipment. Plus, a detailed assessment would be required on any additional attenuation of the building fabric that may be required from a change in equipment, or equipment operational scenarios.**
- **The available capacity of the energy supply from the Utility Network, whether there is additional capacity available above the current provision of 66kVa / 25 MVA per supply available without an upgrade of the system. The current supply has approximately one third spare capacity.**
- **Within the Motorway energy network supply what provisions are made for spare capacity, and then spare conduits to provide additional HV power between substations**
- **From the Substations supply what provisions are made for spare capacity, and then spare conduits to provide additional LV power from the substations**
- **Limits on the spacing of longitudinal jet fans due to in-tunnel noise limitations (for audibility and intelligibility) and proximity to existing tunnel devices.**

### 6.1.3. Potential Future Modifications

Future modifications are expected to be required as a result of 'Unpredicted Events' as outlined in Section 3. Potential future modifications to the tunnel ventilation system have been classified into different categories:

- **OPERATIONAL** - Reconfiguration of system usage and controls: those accomplished by reconfiguration of the existing design;
- **ADDITIONAL EQUIPMENT** - Provision of additional components, such as jet fans, with potential impacts on existing M+E systems;
- **EXPANSION OR CONVERSION OF EXISTING INSTALLATIONS** - Provision of substantial additional system components: those accomplished by significant construction of additional system components and altering the civil works; and
























## 6.1.10. Prioritising Potential Modifications

A number of Potential Modifications have been identified. The selection of the appropriate Modification is dependent on the nature of the events that require the Modification. Below is a 'decision tree' to prioritise the response



Decision Tree Diagram – Potential Ventilation Modifications

Refer to the previous assessment of potential modifications.

On the basis of the assumption that “any air quality issues arising through operation of the tunnel can be readily rectified” the range of potential modifications has been limited to those that would not require an additional or separate Environmental Planning and Assessment Act approval.

However there are additional modifications identified that will require an environmental assessment and approval in order to be implemented. These are:

1. Conversion of the emergency exhaust facilities at Wilson Road and Trelawney Street to ventilation outlets; and
2. Provision of filtration systems to treat in-tunnel air or ventilation outlet air.

## 7. Potential Modifications Identified

Several potential modifications have been identified that are capable of improving the air quality, if this is required because of systemic exceedances in the Approved air quality criteria.

### Operational Modifications:

The following operational practices are suggested for consideration:

1. Increase usage of plant equipment (axial fans and tunnel jet fans). The fans are based on a tunnel vehicle capacity of 4000 pcu / hr at 60 km/h for each mainline tunnel. This far exceeds the predicted traffic volumes in the EIS;
2. Extract additional air from the ventilation outlets by using all the installed fans during short peak periods; and
3. Implement traffic management measures to reduce vehicle emissions within the tunnel, such as ramp metering, lane closures, or in worst case, tunnel closure in the case of congested conditions or stopped traffic on downstream motorways (refer to CoA B7).

### Additional Equipment

The following potential modifications are submitted as readily implementable, subject to detail design:

1. Modification # 1 - investigate the most effective method of increasing the tunnel air flow by increasing the number of jet fans (using a smaller diameter jet fan);
2. Modification # 2 - investigate the most effective method of increasing the tunnel air flow by increasing the capacity of the axial fans within the existing northern and / or southern ventilation outlets

All of these additional fans or increased capacity fans would require further design evaluation to assess the optimal location and the required additional power requirements.

### Conversion of Existing Facilities

This Modification requires an environmental assessment, substantial tunnelling and surface civil and building works, along with potential additional land acquisition. Exact detail design would need to be developed and is dependent on the nature of the air quality issue to be rectified.

### Installation of Filtration

This Modification requires an environmental assessment, substantial tunnelling and surface civil and building works, along with potential additional land acquisition. It can be installed to address specific and targeted in-tunnel air quality, or outlet air quality (potentially improving ambient air quality). Exact detail design would need to be developed and is dependent on the specific nature of the air quality issue to be rectified by a filtration system.



## 8. Conclusion

The tunnel ventilation system is designed to internationally recognised tunnel ventilation standards, namely PIARC for traffic density and throughput, with predicted vehicle emissions applicable to Australia, PIARC 'Road Tunnels: Vehicle Emissions and Air Demand for Ventilation' (2012R05EN).

The ventilation system design capacity is based on the theoretical; maximum throughput of a motorway lane translated to the carriageway tunnel. The design data exceeds by a considerable margin the predicted traffic volumes contained in the NorthConnex EIS.




Figure 2-5 Design analysis A (PCU) relative to traffic design capacity

The likelihood of traffic volumes exceeding the theoretical design capacity of the motorway tunnels is very low. As noted in the SPIR:

*"... the triggers that may lead to this level of variance in traffic volumes (demography, land use, major additions to the road network, traffic generating developments) are not expected within the timeframes considered as part of the assessment of the project."*

It is unlikely that the design criteria adopted for the tunnel ventilation system will be exceeded during tunnel operations. However, in the unlikely event that the in-tunnel air quality or outlet air quality is systemically exceeded, larger capacity or additional jet fans in the tunnel carriageways, can be installed. This may require larger capacity axial fans installed at the outlets to provide better air quality.

In-tunnel air quality can be further improved by conversion of the emergency smoke outlets at Wilson Road and Trelawney Street to tunnel ventilation outlets, thereby providing a capability to extract air and simultaneously supplying fresh ambient air to the tunnel. This modification would be subject to a further Environmental Approval.

Alternatively, if these measures are unable to address specific pollutants, such as particulate matter causing exceedances of the visibility criteria, or NO<sub>2</sub> concentrations leading to exceedances, then consideration could be given to provision of in-tunnel filtration, or provision of outlet filtration depending on the specific pollutants to be addressed. It should be noted that conversion of the intermediate facilities from emergency smoke extracts to permanent ventilation outlets or the provision of additional infrastructure for filtration of tunnel will require a modification to the current Project Approval.

The ventilation system, as designed for the approved Project, does not preclude any of the potential modification options identified in this Report.

# Appendix 1: Approved Air Quality Criteria

## A1 Project Approval Air Quality Requirements:

### In-Tunnel Air Quality – Limits

- E2 The tunnel ventilation system must be designed and operated so that the average concentration of CO and NO<sub>2</sub>, calculated along the length of the tunnel, does not exceed the concentration limit specified for that pollutant in **Table 5**.

**Table 5 – In-tunnel average limits along length of tunnel**

Pollutant	Concentration Limit	Units of measurement	Averaging period
CO	87	ppm	Rolling 15-minute
CO	50	ppm	Rolling 30-minute
NO <sub>2</sub>	0.5	ppm	Rolling 15-minute

- E3 The tunnel ventilation system must be designed and operated so that the concentration of CO as measured at any single point in the tunnel, does not exceed the concentration limit specified for that pollutant in **Table 6** under all conditions (including congested conditions).

**Table 6 – In-tunnel single point exposure limits**

Pollutant	Concentration Limit	Units of measurement	Averaging period
CO	200	ppm	Rolling 3-minute

- E4 The tunnel ventilation system must be designed and operated so that the visibility in the tunnel does not exceed the level specified in **Table 7**.

**Table 7 – In-tunnel visibility limits along length of tunnel**

Parameter	Average extinction coefficient Limit	Units of measurement	Averaging period
Visibility	0.005	m <sup>-1</sup>	Rolling 15-minute

### Ambient Air Quality – Goals

- E2 Should ambient monitoring of air pollutants exceed the following goals, the provisions of Condition E9 shall apply:
- (a) CO – 8 hour rolling average of 9.0 ppm (NEPM);
  - (b) NO<sub>2</sub> – One hour average of 0.12 ppm (245µg/m<sup>3</sup>) (NEPM);
  - (c) PM<sub>10</sub> – 24 hour average of 50µg/m<sup>3</sup> (NEPM); and
  - (d) PM<sub>25</sub> – 24 hour average of 24µg/m<sup>3</sup> (proposed NEPM).

Table 10 – Ventilation Outlet Mass Pollutant Concentrations

Pollutant	100 percentile limit	Units of measurement	Averaging period	Reference conditions
Solid particles	1.1	mg/m <sup>3</sup>	1 hour, or the minimum sampling period specified in the relevant test method, whichever is the greater	Dry, 273K, 101.3kPa
NO <sub>2</sub> or NO or both, as NO <sub>2</sub> equivalent	20	mg/m <sup>3</sup>	1 hour block	Dry, 273K, 101.3kPa
NO <sub>2</sub>	2.0	mg/m <sup>3</sup>	1 hour block	Dry, 273K, 101.3kPa
CO	40	mg/m <sup>3</sup>	1 hour rolling	Dry, 273K, 101.3kPa
VOC (as propane)	1.0	mg/m <sup>3</sup>	1 hour rolling	Dry, 273K, 101.3kPa

---

# Appendix 2: Tunnel Ventilation Design Criteria

## A2 Tunnel Ventilation Design Requirements

The tunnel M&E Systems are designed to meet a two lane configuration.

### A2.1 Design Criteria

#### A2.1.1 Normal Operation Requirements

During normal operation, the tunnel ventilation system shall maintain:

- In-tunnel air quality; and
- External air quality (via dispersion and net portal inflow).

The operation of the ventilation system during normal mode will be controlled automatically by the tunnel ventilation control system, based on traffic, time of day information and feedback from air monitoring sensors.

#### A2.1.2 Congested Operation Requirements

During congested operation (below 20kmph), operational measures to restrict traffic entering the affected tunnel shall be implemented in addition to the tunnel ventilation system to maintain:

- In-tunnel air quality; and
- External air quality (via dispersion and net portal inflow).

#### A2.1.3 Emergency Operation Requirements

During emergency operation, the tunnel ventilation system shall be:

- Capable of performing smoke control by providing a longitudinal air velocity, in line with the critical velocity as determined using the process set out in NFPA 502; and
- Controlled automatically, based on the location of the incident as detected by the fire and control systems).

Emergency Operations, such as smoke control, are designed to provide tenable conditions for emergency egress of tunnel occupants, and also for firefighting personnel (possibly with breathing apparatus) in conducting an emergency response.

This operational mode is not required to meet the Tunnel Air Quality criteria.

#### A2.1.4 Traffic Density/Fleet Mix

The in tunnel air quality requirements to be achieved (as specified in the Environmental Documents) are to be based upon a peak capacity of 4000 PCU/hr at 60 km/hr. The peak traffic data, traffic densities and fleet mix required for the control of in tunnel air quality is identified in Exhibit A SWTC Appendix 18, Section 1.6(b)(i).

#### A2.1.5 In-Tunnel Air Quality Limits

In-tunnel air quality limits are identified in the NorthConnex Planning Approval Conditions (January 2015), Tables 5, 6 and 7 (Refer Appendix A)

#### A2.1.6 Ventilation Outlet Limits

Ventilation outlet limits are identified in the NorthConnex Planning Approval Conditions (January 2015), Table 10. (Refer Appendix A)

### A2.1.7 Vehicle Emissions

Vehicle emissions used in the design of the ventilation system are based upon PIARC Road Tunnels Vehicle Emissions and Air Demand for Ventilation (2012R05EN).

### A2.1.8 Emission Conversion Factors

#### NO<sub>2</sub>:NO<sub>x</sub> Ratio

The NO<sub>2</sub> emissions are determined based on a 10% ratio to the PIARC NO<sub>x</sub> emissions in accordance with Exhibit A SWTC Appendix 18, Section 1.6(b)(iii).

### A2.1.9 Visibility to Solid Particle Conversion

The amounts of solid particles present in the tunnel are determined based on an inverse relationship to the PIARC Visibility emissions in accordance with Exhibit A SWTC Appendix 18, Section 1.6(b)(iv).

### A2.1.10 VOC:CO Ratio

The amount of VOCs present in the tunnel is determined based on a 10% ratio to the PIARC CO emissions in accordance with Exhibit A SWTC Appendix 18, Section 1.6(b)(v).