

# Environment Protection Licence Monitoring Data



Project Name: NorthConnex  
 Environment Protection Licence No: 20570  
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)  
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076  
 Date Published: 14-May-2020  
 Monitoring Data for the Period: 01-April-2020 to 30-April-2020

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Southern MOC WTP	1-Apr-20	1-Apr-20	50	N/A	50	<5	6.5 - 8.5	8.4	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
NC01	2-Apr-20	2-Apr-20	40	4.4	40	N/A	6.5 - 8.5	8.3	None visible	None visible	Special Frequency 1	
Southern MOC WTP	2-Apr-20	2-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	3-Apr-20	3-Apr-20	50	N/A	50	<5	6.5 - 8.5	8.4	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	4-Apr-20	4-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	5-Apr-20	5-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	6-Apr-20	6-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
NC01	7-Apr-20	7-Apr-20	40	2.2	40	N/A	6.5 - 8.5	8.2	None visible	None visible	Special Frequency 1	
Southern MOC WTP	7-Apr-20	7-Apr-20	50	N/A	50	<5	6.5 - 8.5	7.3	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
TRT1	8-Apr-20	8-Apr-20	50	32	50	N/A	6.5 - 8.5	7.8	None visible	None visible	Special Frequency 1	
Southern MOC WTP	8-Apr-20	8-Apr-20	50	N/A	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	9-Apr-20	9-Apr-20	50	N/A	50	<5	6.5 - 8.5	7.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	10-Apr-20	10-Apr-20	50	N/A	50	<5	6.5 - 8.5	8.4	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	11-Apr-20	11-Apr-20	50	N/A	50	<5	6.5 - 8.5	8.3	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample

# Environment Protection Licence Monitoring Data



Project Name: NorthConnex  
 Environment Protection Licence No: 20570  
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)  
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076  
 Date Published: 14-May-2020  
 Monitoring Data for the Period: 01-April-2020 to 30-April-2020

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Southern MOC WTP	12-Apr-20	12-Apr-20	50	N/A	50	<5	6.5 - 8.5	8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	13-Apr-20	13-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	14-Apr-20	14-Apr-20	50	N/A	50	<5	6.5 - 8.5	7.7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	15-Apr-20	15-Apr-20	50	N/A	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	16-Apr-20	16-Apr-20	50	N/A	50	<5	6.5 - 8.5	7.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	17-Apr-20	17-Apr-20	50	N/A	50	<5	6.5 - 8.5	8.4	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	18-Apr-20	18-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	19-Apr-20	19-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	20-Apr-20	20-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	21-Apr-20	21-Apr-20	50	N/A	50	<5	6.5 - 8.5	8.2	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	22-Apr-20	22-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	23-Apr-20	23-Apr-20	50	N/A	50	<5	6.5 - 8.5	8.3	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	24-Apr-20	24-Apr-20	50	N/A	50	<5	6.5 - 8.5	8.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	25-Apr-20	25-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample

# Environment Protection Licence Monitoring Data



Project Name: NorthConnex  
 Environment Protection Licence No: 20570  
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)  
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076  
 Date Published: 14-May-2020  
 Monitoring Data for the Period: 01-April-2020 to 30-April-2020

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Southern MOC WTP	26-Apr-20	26-Apr-20	50	N/A	50	<5	6.5 - 8.5	8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	27-Apr-20	27-Apr-20	50	N/A	50	<5	6.5 - 8.5	8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	28-Apr-20	28-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	29-Apr-20	29-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	30-Apr-20	30-Apr-20	50	N/A	50	<5	6.5 - 8.5	6.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample