

Environment Protection Licence Monitoring Data



Project Name: NorthConnex
 Environment Protection Licence No: 20570
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076
 Date Published: 14-April-2020
 Monitoring Data for the Period: 01-March-2020 to 31-March-2020

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Southern MOC WTP	1-Mar-20	1-Mar-20	50	N/A	50	<5	6.5 - 8.5	6.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	2-Mar-20	2-Mar-20	50	N/A	50	<5	6.5 - 8.5	6.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	3-Mar-20	3-Mar-20	50	N/A	50	<5	6.5 - 8.5	6.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	4-Mar-20	4-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.2	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	5-Mar-20	5-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	6-Mar-20	6-Mar-20	50	N/A	50	<5	6.5 - 8.5	8.4	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	7-Mar-20	7-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.2	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	8-Mar-20	8-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.3	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
NC01	9-Mar-20	9-Mar-20	40	1.4	40	N/A	6.5 - 8.5	6.8	None visible	None visible	Special Frequency 1	
Southern MOC WTP	9-Mar-20	9-Mar-20	50	N/A	50	<5	6.5 - 8.5	7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
SC01	10-Mar-20	10-Mar-20	50	46.3	50	N/A	6.5 - 8.5	8.1	None visible	None visible	Special Frequency 1	
Southern MOC WTP	10-Mar-20	10-Mar-20	50	N/A	50	<5	6.5 - 8.5	6.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	11-Mar-20	11-Mar-20	50	N/A	50	<5	6.5 - 8.5	6.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	12-Mar-20	12-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
TR T1	13-Mar-20	13-Mar-20	50	3	50	N/A	6.5 - 8.5	7.8	None visible	None visible	Special Frequency 1	

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample

Environment Protection Licence Monitoring Data



Project Name: NorthConnex
 Environment Protection Licence No: 20570
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076
 Date Published: 14-April-2020
 Monitoring Data for the Period: 01-March-2020 to 31-March-2020

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Southern MOC WTP	13-Mar-20	13-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	14-Mar-20	14-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
NVF 01	15-Mar-20	15-Mar-20	40	1.5	40	N/A	6.5 - 8.5	8.3	None visible	None visible	Special Frequency 1	
Southern MOC WTP	15-Mar-20	15-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	16-Mar-20	16-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	17-Mar-20	17-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	18-Mar-20	18-Mar-20	50	N/A	50	<5	6.5 - 8.5	7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	19-Mar-20	19-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.1	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
NC01	20-Mar-20	20-Mar-20	40	4.3	40	N/A	6.5 - 8.5	8.2	None visible	None visible	Special Frequency 1	
Southern MOC WTP	20-Mar-20	20-Mar-20	50	N/A	50	<5	6.5 - 8.5	8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	21-Mar-20	21-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	22-Mar-20	22-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	23-Mar-20	23-Mar-20	50	N/A	50	<5	6.5 - 8.5	7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	24-Mar-20	24-Mar-20	50	N/A	50	<5	6.5 - 8.5	7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	25-Mar-20	25-Mar-20	50	N/A	50	<5	6.5 - 8.5	7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample

Environment Protection Licence Monitoring Data



Project Name: NorthConnex
 Environment Protection Licence No: 20570
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076
 Date Published: 14-April-2020
 Monitoring Data for the Period: 01-March-2020 to 31-March-2020

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Southern MOC WTP	26-Mar-20	26-Mar-20	50	N/A	50	<5	6.5 - 8.5	7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	27-Mar-20	27-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	28-Mar-20	28-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.3	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	29-Mar-20	29-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	30-Mar-20	30-Mar-20	50	N/A	50	<5	6.5 - 8.5	7.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
NC01	31-Mar-20	31-Mar-20	40	23.4	40	N/A	6.5 - 8.5	8.2	None visible	None visible	Special Frequency 1	
Southern MOC WTP	31-Mar-20	31-Mar-20	50	N/A	50	<5	6.5 - 8.5	6.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample