

# Environment Protection Licence Monitoring Data



Project Name: NorthConnex  
 Environment Protection Licence No: 20570  
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)  
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076  
 Date Published: 12-June-2020  
 Monitoring Data for the Period: 01-May-2020 to 31-May-2020

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Southern MOC WTP	1-May-20	1-May-20	50	N/A	50	<5	6.5 - 8.5	7.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	2-May-20	2-May-20	50	N/A	50	<5	6.5 - 8.5	7.2	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	3-May-20	3-May-20	50	N/A	50	<5	6.5 - 8.5	7.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
TR T1	4-May-20	4-May-20	50	38	50	N/A	6.5 - 8.5	7.9	None visible	None visible	Special Frequency 1	
Southern MOC WTP	4-May-20	4-May-20	50	N/A	50	9.5	6.5 - 8.5	8.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	5-May-20	5-May-20	50	N/A	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	6-May-20	6-May-20	50	N/A	50	<5	6.5 - 8.5	7.1	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	7-May-20	7-May-20	50	N/A	50	<5	6.5 - 8.5	7.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	8-May-20	8-May-20	50	N/A	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	9-May-20	9-May-20	50	N/A	50	<5	6.5 - 8.5	8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	10-May-20	10-May-20	50	N/A	50	<5	6.5 - 8.5	7.4	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	11-May-20	11-May-20	50	N/A	50	<5	6.5 - 8.5	7.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	12-May-20	12-May-20	50	N/A	50	11	6.5 - 8.5	7.7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	13-May-20	13-May-20	50	N/A	50	<5	6.5 - 8.5	7.4	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample

# Environment Protection Licence Monitoring Data



Project Name: NorthConnex  
 Environment Protection Licence No: 20570  
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)  
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076  
 Date Published: 12-June-2020  
 Monitoring Data for the Period: 01-May-2020 to 31-May-2020

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Southern MOC WTP	14-May-20	14-May-20	50	N/A	50	<5	6.5 - 8.5	7.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	15-May-20	15-May-20	50	N/A	50	<5	6.5 - 8.5	7.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	16-May-20	16-May-20	50	N/A	50	<5	6.5 - 8.5	7.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	17-May-20	17-May-20	50	N/A	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	18-May-20	18-May-20	50	N/A	50	<5	6.5 - 8.5	7.3	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
NC01	19-May-20	19-May-20	40	23.1	50	N/A	6.5 - 8.5	7.3	None visible	None visible	Special Frequency 1	
Southern MOC WTP	19-May-20	19-May-20	50	N/A	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	20-May-20	20-May-20	50	N/A	50	<5	6.5 - 8.5	7.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	21-May-20	21-May-20	50	N/A	50	<5	6.5 - 8.5	7.4	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	22-May-20	22-May-20	50	N/A	50	<5	6.5 - 8.5	7.3	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	23-May-20	23-May-20	50	N/A	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	24-May-20	24-May-20	50	N/A	50	<5	6.5 - 8.5	7.1	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	25-May-20	25-May-20	50	N/A	50	<5	6.5 - 8.5	6.9	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	26-May-20	26-May-20	50	N/A	50	<5	6.5 - 8.5	6.7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
NC01	27-May-20	27-May-20	40	13.7	50	N/A	6.5 - 8.5	7.7	None visible	None visible	Special Frequency 1	

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample

# Environment Protection Licence Monitoring Data



Project Name: NorthConnex  
 Environment Protection Licence No: 20570  
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)  
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076  
 Date Published: 12-June-2020  
 Monitoring Data for the Period: 01-May-2020 to 31-May-2020

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Southern MOC WTP	27-May-20	27-May-20	50	N/A	50	<5	6.5 - 8.5	8.3	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	28-May-20	28-May-20	50	N/A	50	<5	6.5 - 8.5	8.2	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	29-May-20	29-May-20	50	N/A	50	<5	6.5 - 8.5	8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	30-May-20	30-May-20	50	N/A	50	<5	6.5 - 8.5	7.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Southern MOC WTP	31-May-20	31-May-20	50	N/A	50	<5	6.5 - 8.5	7.4	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample